

# CITY OF CORTEZ 2021 DRINKING WATER QUALITY REPORT

For Calendar Year 2020

Public Water System ID: CO0142200

Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca.

---

The City of Cortez is pleased to present to you with this year's water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water. Please contact Rich Landreth, Water Treatment Plant Superintendent, at 970-565-9824 with any questions or for public participation opportunities that may affect water quality.

---

## General Information

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791) or by visiting [epa.gov/ground-water-and-drinking-water](http://epa.gov/ground-water-and-drinking-water).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants, call the EPA Safe Drinking Water Hotline at (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants:** viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants:** salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides:** may come from a variety of sources, such as agriculture, urban storm water runoff, and residential uses.
- Radioactive contaminants:** can be naturally occurring or be the result of oil and gas production and mining activities.
- Organic chemical contaminants:** including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

## Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems (especially for pregnant women and young children). It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home's plumbing. If you are concerned about lead in your water, you may wish to have your water tested. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Additional information about lead in drinking water, the methods of testing, and the steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at [epa.gov/safewater/lead](http://epa.gov/safewater/lead).

## Source Water Assessment and Protection (SWAP)

The Colorado Department of Public Health and Environment may have provided us with a Source Water Assessment Report for our water supply. For general information or to obtain a copy of the report please visit [wqcdcompliance.com/ccr](http://wqcdcompliance.com/ccr). The report is located under "Guidance: Source Water Assessment Reports." Search the table using 142200, CORTEZ CITY OF, or by contacting Water Treatment Plant Superintendent Rich Landreth at 970-565-9824. The Source Water Assessment Report provides a screening-level evaluation of potential contamination that *could* occur. It *does not* mean that the contamination *has or will* occur. We can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination threats. This can help us ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan. Potential sources of contamination in our source water area are listed on the next page.

Please contact us to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Quality Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services we provide and the quality water we deliver to you every day.

## Our Water Source

<u>Source</u> <u>Water Type - Source Type</u>	<u>Potential Source(s) of Contamination</u>
MCPHEE RESERVOIR  (Surface Water-Intake)	Permitted Wastewater Discharge Sites; Aboveground, Underground and Leaking Storage Tank Sites; Solid Waste Sites; Existing/Abandoned Mine Sites; Other Facilities; Commercial/Industrial/Transportation; High Intensity Residential; Low Intensity Residential; Urban Recreational Grasses; Row Crops; Pasture / Hay; Deciduous Forest; Evergreen Forest; Mixed Forest; Septic Systems; Oil / Gas Wells; Road Miles

### Terms and Abbreviations

- **Maximum Contaminant Level (MCL)** – The highest level of a contaminant allowed in drinking water.
- **Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.
- **Health-Based** – A violation of either a TT or MCL.
- **Non-Health-Based** – A violation that is not a TT or MCL.
- **Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.
- **Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Contaminant Level Goal (MCLG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Violation (No Abbreviation)** – Failure to meet a Colorado Primary Drinking Water Regulation.
- **Formal Enforcement Action (No Abbreviation)** – Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.
- **Variance and Exemptions (V/E)** – Department permission not to meet an MCL or treatment technique under certain conditions.
- **Gross Alpha (No Abbreviation)** – Gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222, and uranium.
- **Picocuries per liter (pCi/L)** – Measure of the radioactivity in water.
- **Nephelometric Turbidity Unit (NTU)** – Measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the typical person.
- **Compliance Value (No Abbreviation)** – Single or calculated value used to determine if regulatory contaminant level (e.g. MCL) is met. Examples of calculated values are the 90<sup>th</sup> Percentile, Running Annual Average (RAA), and Locational Running Annual Average (LRAA).
- **Average (x-bar)** – Typical value.
- **Range (R)** – Lowest value to the highest value.
- **Sample Size (n)** – Number or count of values (i.e. number of water samples collected).
- **Parts per million = Milligrams per liter (ppm = mg/L)** – One part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion = Micrograms per liter (ppb = ug/L)** – One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Not Applicable (N/A)** – Does not apply or not available.
- **Level 1 Assessment** – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- **Level 2 Assessment** – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

---

### Detected Contaminants

The City of Cortez routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table(s) show all detections found in the period of January 1 to December 31, 2020, unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one-year-old. Violations and Formal Enforcement Actions, if any, are reported in the next section of this report.

**NOTE:** Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section, then no contaminants were detected in the last round of monitoring.

**Disinfectants Sampled in the Distribution System**  
**TT Requirement:** At least 95% of samples per period (month or quarter) must be at least 0.2 ppm OR  
 If sample size is less than 40 no more than 1 sample is below 0.2 ppm  
**Typical Sources:** Water additive used to control microbes

Disinfectant Name	Time Period	Results	Number of Samples Below Level	Sample Size	TT Violation	MRDL
Chlorine	December 2020	<u>Lowest period</u> percentage of samples meeting TT requirement: 100%	0	10	No	4.0 ppm

**Lead and Copper Sampled in the Distribution System**

Contaminant Name	Time Period	90 <sup>th</sup> Percentile	Sample Size	Unit of Measure	90 <sup>th</sup> Percentile AL	Sample Sites Above AL	90 <sup>th</sup> Percentile AL Exceedance	Typical Sources
Copper	08/10/2020 to 08/11/2020	0.1	21	ppm	1.3	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead	08/10/2020 to 08/11/2020	4.8	21	ppb	15	2	No	Corrosion of household plumbing systems; Erosion of natural deposits

**Summary of Turbidity Sampled at the Entry Point to the Distribution System**

Contaminant Name	Sample Date	Level Found	TT Requirement	TT Violation	Typical Sources
Turbidity	Month: January	<u>Highest single</u> measurement: 1 NTU	Maximum 1 NTU for any single measurement	Yes	Soil Runoff
Turbidity	Month: December	<u>Lowest monthly</u> percentage of samples meeting TT requirement for our technology: 100 %	In any month, at least 95% of samples must be less than 0.1 NTU	No	Soil Runoff

**Total Organic Carbon (Disinfection Byproducts Precursor) Removal Ratio of Raw and Finished Water**

Contaminant Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	TT Minimum Ratio	TT Violation	Typical Sources
Total Organic Carbon Ratio	2020	1.51	1.12 to 3.17	12	Ratio	1.00	No	Naturally present in the environment

\*If minimum ratio not met and no violation identified, then the system achieved compliance using alternative criteria.

**Secondary Contaminants\*\***  
 \*\*Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin, or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.

Contaminant Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	Secondary Standard
Sodium	2016	13.5	13.5 to 13.5	1	ppm	N/A

**Disinfectants Sampled in the Distribution System**

**TT Requirement:** At least 95% of samples per period (month or quarter) must be at least 0.2 ppm OR

If sample size is less than 40 no more than 1 sample is below 0.2 ppm

**Typical Sources:** Water additive used to control microbes

Disinfectant Name	Time Period	Results	Number of Samples Below Level	Sample Size	TT Violation	MRDL
-------------------	-------------	---------	-------------------------------	-------------	--------------	------

**Inorganic Contaminants Sampled at the Entry Point to the Distribution System**

Contaminant Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
Barium	2016	0.1	0.1 to 0.1	1	ppm	2	2	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	2016	6.3	6.3 to 6.3	1	ppb	100	100	No	Discharge from steel and pulp mills; erosion of natural deposits
Nitrate	2020	0.02	0.02 to 0.02	1	ppm	10	10	No	Runoff from fertilizer use; leaching from septic tanks, sewage, erosion of natural deposits
Selenium	2016	1.2	1.2 to 1.2	1	ppb	50	50	No	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

**Disinfection Byproducts Sampled in the Distribution System**

Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
Total Haloacetic Acids (HAA5)	2020	34.1	25.2 to 50.6	8	ppb	60	N/A	No	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM)	2020	51.76	36.1 to 59	8	ppb	80	N/A	No	Byproduct of drinking water disinfection



*City of Cortez  
Water Treatment Plant  
Rich Landreth, Superintendent  
970.565.9824*



**Violations, Significant Deficiencies, and Formal Enforcement Actions**

**Health-Based Violations**

**Maximum contaminant level (MCL) violations:** Test results for this contaminant show that the level was too high for the time period shown. Please read the information shown below about potential health effects for vulnerable populations. This is likely the same violation that we told you about in a past notice. We are evaluating, or we already completed an evaluation, to find the best way to reduce or remove the contaminant. If the solution will take an extended period of time, we will keep you updated with quarterly notices.

**Treatment technique (TT) violations:** We failed to complete an action that could affect water quality. Please read the information shown below about potential health effects for vulnerable populations. This is likely the same violation that we told you about in a past notice. We were required to meet a minimum operation/treatment standard, we were required to make upgrades to our system, or we were required to evaluate our system for potential sanitary defects, and we failed to do so in the time period shown below. If the solution will take an extended period of time, we will keep you updated with quarterly notices.

Name	Description	Time Period	Health Effects	Compliance Value	TT Level or MCL
TURBIDITY	EXCEEDED TURBIDITY (CLOUDINESS) LEVELS FOR SURFACE WATER FILTRATION	01/01/2020 - 01/31/2020	Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.	N/A	N/A

**Additional Violation Information**

Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Describe the steps taken to resolve the violation(s), and the anticipated resolution date:

On January 2, 2020 a flow meter malfunctioned on one of our filters allowing more flow than the filter normally handles. This caused a short duration spike in turbidity from the filter causing the violation noted. The malfunctioning flow meter was replaced and we made an adjustments so that the filter cannot flow more than the maximum for the filter. At the time there were multiple filters running consequently at no time did the water entering the distribution system exceed turbidity standards.



The City of Cortez recently completed our Source Water Protection Plan (SWPP). After a multi-year effort, we now have a written plan that will help us protect our drinking water supply.

To review the Plan go to the City's website at: <http://www.cityofcortez.com/229/Water>